



NOTE

RISERS TO BE CONSTRUCTED WHERE SEWER DEPTH EXCEEDS 12'-0". FOR PIPE MATERIAL SEE SPECIFICATIONS ON PLANS.

GREATER THAN 45 ° CONNECTION TO MAIN NOT ALLOWED

RISER CONNECTION FOR SERVICE LATERAL

Fox Metro
Water Reclamation District

DESIGNED	FMWRD	REVISION	2017
DRAWN	KZ	D Riser & Stone Note	01/30/06
APPROVED	KZ, MF	E Riser & Conflict Notes	03/19/07
DATE	05-15-00	F Conflict Note	04/29/08
SCALE	NTS	G Misc. Note Revisions	12/15/16
SHEET	1	CAD DWG.	REVISION G
OF	1	JOB NO.	