



\* ALL BUILDING CONNECTIONS ARE REQUIRED TO BE OVERHEAD. STUBS SHALL BE AT A DEPTH OF NO MORE THAN 6'-7'. WHERE CONFLICTS EXIST BETWEEN THE WATERMAIN (OR WATER SERVICES) AND SANITARY SERVICES, INSTALL SANITARY TO MAXIMUM DEPTH TO AVOID CONFLICT. IN THE EVENT OF CONFLICTS, REFER TO "77 ILL. ADMIN. CODE PART 890, ILLINOIS PLUMBING CODE", LATEST EDITION.

### NOTE

SELECT GRANULAR BACKFILL, REQUIRED UNDER PAVED AREAS, TO BE APPROVED BY APPROPRIATE CITY OR VILLAGE.

**GREATER THAN 45 ° CONNECTION AT MAIN NOT ALLOWED**

### SERVICE CONNECTION

**Fox Metro**  
Water Reclamation District

DESIGNED	FMWRD	REVISION	2017
DRAWN	KZ	E Inset & Note Revisions	03/19/07
APPROVED	KZ, MF	F Note Revisions	04/29/08
DATE	05-12-00	G Note Revisions	05/10/12
SCALE	NTS	H Overhead & Misc. Note Revisions	02/24/17
SHEET	1	CAD DWG.	REVISION
OF	1	JOB NO.	H