



1135 South Lake Street • Montgomery, Illinois 60538
Engineering Inquiries (630) 301-6882
Inspections (630) 301-6811 • FAX (630) 897-6094

Rev: 2/11/2021

CONTRACTOR NOTICE

Fox Metro Water Reclamation District

IMPORTANT – PLEASE READ!!

The following list represents costly problems or violations that commonly occur during or after construction. Our goal is to make everyone aware of these problems and hopefully reduce unnecessary delays, expenses, and fines.

In order to perform new construction or repair work on any private sanitary or water service, the following must be completed before work may commence:

- A \$25,000 license & permit bond made out to “Fox Metro Water Reclamation District” must be received and approved for new construction or repair work. Please instruct your insurance company to call out the work to be performed as “sanitary sewer construction”.
 - A District permit for new construction or a repair permit needs to be issued.
 - An inspection is required by the District. To save a \$50 same day inspection fee, please provide twenty-four (24) hour notice.
1. All public sanitary sewer construction must have an IEPA permit **and** plan approval letter on file at the District prior to commencing. Please provide our office with 48-hour notification to verify this before starting construction.
 2. To prevent unnecessary flow or discharge into the existing sanitary system, all new sanitary construction must be securely plugged and maintained by the contractor. The plug(s) may only be removed after permission has been obtained from the municipality or from the District’s engineering department. All construction drainage must be properly removed from the new sanitary sewer system.
 3. All newly proposed private building sewer construction must have a connection permit from the District. In addition, this work shall be inspected by the District. Please call (630) 301-6811 by 3:00 pm the day prior to the requested inspection time. No building sewers shall be installed until all proposed public sewers have been tested and approved by the District and a final recorded subdivision plat is submitted.

4. All domestic water service installations (except for the Village of Oswego and the United City of Yorkville) are to be inspected by the District. Any final connection(s) to any building, made by any plumber or excavator, shall also be inspected by the District. **Do not backfill this connection before this inspection is completed.**
5. All sanitary manholes are to be sealed (exterior of chimney & barrels) and vacuum tested. Any disruption of these manholes will break the seal(s), requiring a costly resealing and retesting process. Please stay clear of all manholes.

For questions regarding permitting and construction, call the District's engineering department at (630) 301-6882. For questions regarding inspections or to report violations, open manholes, or other issues please call (630) 301-6811.