

## NOTE

WHERE EXISTING SEWERS ARE 14" AND LESS, THE INVERT(S) OF NEW PIPE(S) SHALL BE DETERMINED BY MATCHING THE PROPOSED ELEVATION(S) TO THE TOP OF DOWNSTREAM PIPE. FOR SEWERS 15" OR GREATER, SEE APPROVED PLANS FOR INVERT INFORMATION. ALL FLOW CHANNELS SHALL BE PRECAST INTO THE BENCH.

## TYPE "C" MANHOLE

## Fox Metro Water Reclamation District

	DESIGNED	FMWRD	F	REVISION		2023
ı	DRAWN	KZ	F	Note Revisions		04/29/08
	APPROVED	KZ, MF	G	Misc. Note Revisions		03/09/17
ı	DATE 05-15-00		Н	"NOTE" Rev.— determine invert		07/23/2020
I	SCALE	NTS	J	Expanded Polypropylene adj.	rings	6/27/2022
I	SHEET 1		CAD DWG. REVI		REVIS	ION
	OF	1	7	OB NO.		H