



NOTES

* TO ESTABLISH THE INVERT OF THE NEW PIPE(S) WHERE THE EXISTING SEWER IS 14" DIA. OR LESS, MATCH THE ELEVATION OF THE TOP OF THE INCOMING PIPE TO THE TOP OF THE EXISTING DOWNSTREAM PIPE. FOR EXISTING SEWERS GREATER THAN OR EQUAL TO 15", SEE APPROVED PLANS.

SERVICES: NO DROP CONNECTIONS ALLOWED. CORE AT THE MANHOLE BOTTOM PER ABOVE WITH A SINGLE CONNECTION, THEN, TO ESTABLISH UPSTREAM LINE/GRADE, USE TWO 45 DEGREE FITTINGS.

PIPE TO EXISTING MANHOLE CONNECTION

Fox Metro
Water Reclamation District

DESIGNED	FMWRD	REVISION	2022
DRAWN	KZ	E Grout Note	01/30/06
APPROVED	KZ, MF	F Note Additions	04/28/08
DATE	05-15-00	G "Notes" revision	02/9/17
SCALE	NTS	H Revise *NOTES regarding new invert	12/29/2020
SHEET	1	CAD DWG.	REVISION
OF	1	JOB NO.	H