



NOTE

FOR SERVICE PIPE MATERIAL SEE SPECIFICATIONS ON PLANS. 6'-7' MAX. DEPTH FOR ALL RESIDENTIAL STUBS.

GREATER THAN 45 ° CONNECTION TO MAIN NOT ALLOWED

RISER CONNECTION FOR SERVICE LATERAL

Fox Metro
Water Reclamation District

DESIGNED	FMWRD	REVISION	2022
DRAWN	KZ	E Riser & Conflict Notes	03/19/07
APPROVED	KZ, MF	F Conflict Note	04/29/08
DATE	05-15-00	G Misc. Note Revisions	12/15/16
SCALE	NTS	H "NOTE": 12' riser note removed	12/29/2020
SHEET	1	CAD DWG.	REVISION
OF	1	JOB NO.	H