



* ALL BUILDING CONNECTIONS ARE REQUIRED TO BE OVERHEAD. STUBS AT THE RIGHT OF WAY SHALL BE CONSTRUCTED TO NO DEEPER THAN 6'-7'. WHERE CONFLICTS EXIST BETWEEN THE WATERMAIN (OR WATER SERVICES) AND SANITARY SERVICES, INSTALL SANITARY TO MAXIMUM DEPTH TO AVOID CONFLICT. IN THE EVENT OF CONFLICTS, REFER TO '77 ILL. ADMIN. CODE PART 890, ILLINOIS PLUMBING CODE', LATEST EDITION.

NOTE

SELECT GRANULAR BACKFILL, REQUIRED UNDER PAVED AREAS, TO BE APPROVED BY APPROPRIATE CITY OR VILLAGE.

GREATER THAN 45 ° CONNECTION AT MAIN NOT ALLOWED

SANITARY SERVICE CONNECTION

Fox Metro
Water Reclamation District

DESIGNED	FMWRD	REVISION	2022
DRAWN	KZ	F	Note Revisions 04/29/08
APPROVED	KZ, MF	G	Note Revisions 05/10/12
DATE	05-12-00	H	Overhead & Misc. Note Revisions 02/24/17
SCALE	NTS	I	Depth of stub at R.O.W. note rev. 07/23/2020
SHEET	1	CAD DWG.	REVISION
OF	1	JOB NO.	